

EC690081

EMPTY BOARD FOR CONSTR. SITE FOR 19+19 MOD. - 6 VERT. INT.LOCKED SOCKETS

Industrial > Distribution boards > Distribution boards > Series acs - panel system 800 > Energy distributor for construction site > Unwired versions

Technical Symbols/Marks/Approvals

IP65 | GWT 650° | RoHS II | MADE IN ITALY

Norms

EN 61439-1 EN 61439-4

Description

ASC-type distribution board, factory-assembled in series. Manufactured in shock-resistant, two-component technopolymer. IK10 impact resistance rating, suitable for heavy-duty applications. Galvanized steel DIN rail. Double door closure with triangular key included. MCB protection for outlets located in a control panel with a triangular lock, key included. Wall-mounting capability via metal brackets or on a metal stand. Carrying handles integrated into the casing. Open base for cable exit. Operation possible with plugs inserted even when the door is closed. 180° door opening angle. Manufactured in compliance with EN 60670-1, EN 60670-24, EN 61439-1, EN 61439-4 standards.
Recommended installation: mobile or semi-fixed. Recommended use: construction sites or temporary workplaces where access is restricted to authorized and qualified personnel. Empty construction site board pre-arranged for 19+19 modules for 6 vertical interlocked sockets or 12 fixed 16/32A sockets with 690F4 flanges (not supplied). Complete with emergency stop button with twist-to-reset, M40 cable gland, and standard locks. Rated current 125A. Protection degree IP65. Dimensions 870x720x375 mm.

Information, dimensions, diagrams and images are provided for informational purposes only and are current as of the date indicated. These elements may be subject to change at any time.

Etim

GROUP EG000023 - Distribution boards

CLASS EC000484 - Energy distributor for construction site

Rated current	125 A	**Leakage current type**	Other	**Degree of protection (IP)**	IP65
Width	870 mm	**Height**	720 mm	**Depth**	375 mm
Model	Distributor cabinet	**Housing material**	Plastic	**Number of socket outlets with protective contact CEE 7/3 (type F)**	0
Number of socket outlets Swiss standard type 13	0	**Number of socket outlets Swiss standard type 15**	0	**Number of socket outlets Swiss standard type 23**	0
Number of socket outlets Swiss standard type 25	0	**Number of miniature circuit breakers (MCB)**	0	**Rated voltage**	400 V
Number of CEE socket outlets (IEC 60309) 16 A / 24 V / 2P (L, N)	0	**Number of CEE socket outlets (IEC 60309) 16 A / 230 V / 3P (L, N, PE)**	0	**Number of CEE socket outlets (IEC 60309) 16 A / 230 V / 5P (1, 2, 3, N, PE)**	0
Number of CEE socket outlets (IEC 60309) 16 A / 400 V / 4P (1, 2, 3, PE)	0	**Number of CEE socket outlets (IEC 60309) 16 A / 400 V / 5P (1, 2, 3, N, PE)**	0	**Number of CEE socket outlets (IEC 60309) 32 A / 230 V / 4P (1, 2, 3, PE)**	0
Number of CEE socket outlets (IEC 60309) 32 A / 400 V / 4P (1, 2, 3, PE)	0	**Number of CEE socket outlets (IEC 60309) 32 A / 400 V / 5P (1, 2, 3, N, PE)**	0	**Number of CEE socket outlets (IEC 60309) 63 A / 230 V / 4P (1, 2, 3, PE)**	0
Number of CEE socket outlets (IEC 60309) 63 A / 400 V / 5P (1, 2, 3, N, PE)	0	**Number of CEE socket outlets (IEC 60309) 125 A / 230 V / 4P (1, 2, 3, PE)**	0	**Number of CEE socket outlets (IEC 60309) 125A / 400 V / 5P (1, 2, 3, N, PE)**	0
Number of meter panels	0	**Main switch**	None	**Number of poles main switch**	0
Number of earth leakage switches 10 mA	0	**Number of earth leakage switches 30 mA**	0	**Number of earth leakage switches 100 mA**	0
Number of earth leakage switches 300 mA	0	**Emergency stop button**	Yes	**Suitable according to IEC/EN 61439-4**	Yes

Documentation available for download



Instruction booklet

GUIDA DI RIFERIMENTO QUADRI DA CANTIERE TIPO 69008.pdf

Information, dimensions, diagrams and images are provided for informational purposes only and are current as of the date indicated. These elements may be subject to change at any time.

Barcode



8033954879028

Unit

1 NR

1.025x0.395x0.74 [m]

27 [kg]

Information, dimensions, diagrams and images are provided for informational purposes only and are current as of the date indicated. These elements may be subject to change at any time.